

TOP VIEW (UNIT SHOWN IN OPEN POSITION)





NOTES: 1.UNIT IS FURNISHED WITH WALL MOUNTING BRACKET AND 6 OZ (0,18 L)BOTTLE OF BACTERIOSTATIC ADDITIVE TO PRESERVE WATER.

2.WALL BRACKET MOUNTING HOLES ARE POSITIONED

1-7/16" (37 mm) ABOVE THE UNIT.


3.UNIT IS REQUIRED TO BE MOUNTED SO THE


SPRAY HEADS ARE POSITIONED BETWEEN 33" (840 mm) AND

45" (1140 mm) FROM THE FLOOR PER ANSI Z358.1.

4.UNIT WEIGHS 15 LBS (6,8 kg) EMPTY, 156 LBS (70,8 kg) FULL.







UNITS (EXCEPT THOSE WITH SELF-CLOSING VALVES) COMPLY WITH THE REQUIREMENTS OF ANSI Z358.1. TEST ALL EMERGENCY EQUIPMENT AT LEAST WEEKLY.

Krusman 021-14 92 00

KN1540 portable eye wash 60L

Godkänd Av

ISO 2768-m

Ritad/Konstruerad Av

CAD PRODUCED DRAWING - NO MANUAL REVISION ALLOWED

														C		1	(1)
										CONTRACT NO.							
										WORK ORDER NO.							
										DRAWN BY			Portable eye wash	601			
										DATE							
										SCALE			KN1540				
										CHECKED			CONSORTIUM OF	CAD FILE			
			С	ISSUE FOR REVIEW	02/11/1	FA	RH	DK		DATE					AREA LOCATION		
			В	ISSUE FOR REVIEW	05/03/1	JH	FA	DK		APPROVED			CLIENT	09		DLKP	
			Α	ISSUE FOR REVIEW	02/02/1	FA.	JH	DK		DATE			(39275-U)		DRAWING NO.		REV. NO.
DRAWING NO.	REV.	REFERENCE DRAWINGS	REV.	DESCRIPTIONS	DATE	DRAWN	CHK'D CONTRACTO		CHK'D APP'D PCSB		CONTRACTOR	PCSB	THE ORIGINAL AND ALL COPIES OF THIS DRAWING TOGETHER WITH THE COPYRIGHT THERE OF ARE THE SOLE PROPERTY OF PCSB	P	0001	1/1	В